

GENERAL NOTES:

1. All work embodied on these plans shall be done in conformity with applicable provisions of Specifications No. 2271.
2. All vitrified clay pipe house connections shall be constructed on an upward grade of two percent from main sewer & shall extend from the main sewer to property line.
3. 8" x 4" wyes with connecting sewers to be constructed are shown in plan thus: [illegible]
4. All house connections are approximate and exact locations shall be determined in the field.
5. Bench Mark: "L" iron North East corner Alameda Ave. & Holly Vista Blvd. Elv. 1230.46' M.S.L.

517

DEPARTMENT OF ENGINEERING
CITY OF SAN BERNARDINO

NEWPORT AVENUE SEWER

A.T. & S.F. RAIL ROAD to LYNWOOD AVENUE

SUBMITTED BY
APPROVED January 14, 1957
Ronald E. Wolfard
CITY ENGINEER
REGISTERED CIVIL ENGINEER

REFERENCE
DRAWN BY R.N.W.
CHECKED BY

DRAWING No. 2494
SHEET 1

82/238